



ASBESTOS DUST ANALYSIS

By: TRANSMISSION ELECTRON MICROSCOPY

Client: SAQ Environmental Engineers, Inc.
PO Box 155
Manati, PR 00674

CEI Lab Code: T14-1592

Date Received: 07-18-14

Date Analyzed: 07-21-14

Date Reported: 07-22-14

Project: Jorge L Perez Valdivieso School; HOMECA

TEM DUST WIPE (ASTM D6480-05)

Client ID Lab ID	Area Sampled (cm ²)	Area Analyzed (mm ²)	Filtration Factor	Analytical Sensitivity (s/cm ²)	# of Structures	Asbestos Type	Concentration (s/cm ²)
HOM-W- BLANK-01 T28307	BLANK	0.097	10		0	None Detected	
HOM-W- CR13-02 T28308	100	0.097	10	990	0	None Detected	<990
HOM-W- CR13-03 T28309	100	0.097	10	990	0	None Detected	<990
HOM-W- CR13-04 T28310	100	0.097	10	990	0	None Detected	<990

This report may not be reproduced, except in full, without written approval by CEI LABS. CEI LABS makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results.

ANALYST:

Rachael Polmanteer

APPROVED BY:

Tianbao Bai, Ph.D.
Laboratory Director



107 New Edition Court Cary NC 27511
Tel: 866-481-1412; Fax: 919-481-1442

T14-1592(4)
T28307-T28310
CHAIN OF CUSTODY

LAB USE ONLY:
CEI Lab Code:
CEI Lab I.D. Range:

COMPANY CONTACT INFORMATION	
Company: SAQ Environmental Engineers, Inc.	Client #:
Address: PO Box 155 Manati, PR 00674	Job Contact: Samuel A. Quinones
	Email: samuelq@saqee.com
	Tel: 787-374-6187
Project Name: <i>Jose L</i> Perez Valdivieso School	Fax:
Project ID #: HOMECA	P.O. #:


ASBESTOS	METHOD	TURN AROUND TIME					
		4 HR*	8 HR*	24 HR	2 DAY	3 DAY	5 DAY
PLM BULK	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT (400)	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT (1000)	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM GRAVIMETRIC	EPA 600		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM GRAV w POINT COUNT	EPA 600		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PCM AIR	NIOSH 7400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	AHERA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR	NIOSH 7402	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM BULK	CHATFIELD		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM DUST WIPE	ASTM D6480-05	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM DUST MICROVAC	ASTM D5755-09	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM QUALITATIVE	CEI LABS	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD PAINT	METHOD	4 HR**	8 HR**	24 HR**	2 DAY	3 DAY	5 DAY
LEAD PAINT	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD WIPE	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD SOIL	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD AIR	NIOSH 7082				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REMARKS: <i>Wipe samples for ASTM D6480-05 analyses.</i>		<input type="checkbox"/>	Accept Samples
		<input type="checkbox"/>	Reject Samples
Relinquished By:	Date/Time	Received By:	Date/Time
<i>Y. Jang</i>	<i>07/17/14/14:00</i>	<i>AJ386</i>	<i>07/17/14/14:20</i>
<i>AJ386</i>	<i>07/17/14/14:50</i>	<i>[Signature]</i>	<i>7/18/14 11:50</i>

*Call to confirm RUSH analysis.

Samples will be disposed of 30 days after analysis

**TAT's are not available. Lead samples are subcontracted for analysis to an ELLAP accredited lab.



Company: SAQ Environmental Engineers, Inc.	Job Contact: Samuel A Quinones
Project Name: : Jose I Perez Valdivieso School	
Project ID #: HOMECA	Tel: 787-374-6187

Page _____ of _____